

Requirements for Tents, Canopies and other Membrane Structures to be erected within North Cornwall Township

- 1. Installation of any tent, canopy or membrane structure must comply with the most current version of the International Fire Code.**
- 2. Scaled detailed site plan showing lot lines, buildings, all other structures, parking areas, and proposed location of tent, canopies and/or other membrane structures.**
- 3. Tents, canopies and/or other membrane structures may not be located within 20' of any lot lines, buildings, other structures, parked vehicles and internal combustion engines. Guy wires and support ropes are considered part of the structure for determining required distances.**
- 4. Certificate of insurance must be presented when applying for permit.**
- 5. Certificate of Flame treatment must include name and address of owner, date of last treatment, name of chemical applied and test agency/standard used for fabric testing.**
- 6. Installation of any of the above may not impede or obstruct any required parking, travel lane and/or clear site at intersections.**
- 7. Hay, sawdust and shavings are prohibited in any tent, canopy or membrane structure.**
- 8. Combustible materials may not be stored within 20' of any tent, canopy or membrane structure.**
- 9. Combustible vegetation is prohibited within 20' of any tent, canopy or membrane structure.**
- 10. Smoking is prohibited within or around any tent, canopy or membrane structure.**
- 11. No smoking signs must be posted on all sides of any tent, canopy or membrane structure.**
- 12. Open flames, devices emitting flames, fire, heat, heaters, combustible liquids, gases, charcoal or cooking are prohibited within or around any tent, canopy or membrane structure.**
- 13. Trash must be removed daily during period used for public use.**
- 14. Class 2-A fire extinguishers must be available within any tent, canopy or membrane structure.**
- 15. Items stored under any tent, canopy or membrane structure must have at least 3'+ clearance between the fabric and contents.**
- 16. Generators and/or any internal combustion source must be at least 20' + from any tent, canopy or membrane structure.**
- 17. If fireworks are being sold, the compliance to all state and federal guideline apply.**